



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/12/09

Code 32.05-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title IRC		Edition 2009
Section number and title R311.3.2 Floor Elevation for other Exterior Doors		Page
Proponent Jeff Washler	Title	
Address 3435 CR 52 Auburn, IN 46706		Phone 260.925.8427
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Exception 2. When the stairs serve a sliding patio door the height of the top riser shall be measured from the tread to the finished floor instead of the threshold.</p>		
REASON AND FISCAL IMPACT		
<p>The height and shape of the threshold on a sliding patio door causes people to not normally step on the threshold. Measuring the height this way will create a more even set of stairs for people to walk on.</p> <p>Should be no fiscal impact.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		